



Gujarat Water Supply & Sewerage Board,

"Jal Bhavan", Sector-10-A.

Opp. Air force Station,

Gandhinagar-382010. Ph. (079) 23251092

Fax-(079) 23251094/23225979

Mat.cell (c) Ph. 232-51092, Fax - 232-40631

197
2

No.CE (Mat)/Vendor Selection/Valves/4265/2024

DL. 27.4.2021

To,

M/s. Durga Valves PVT.LTD.

Village & Post: Mahiserkha,

Tusiberia Road (Near Ideal School).

PS: Uluberia, Dist: Howrah- 711 303

Email :- gujarat@durgavalves.com

kolkatta@durgavalves.com,

info@durgavalves.com

Sub: Selection of vendors for purchase of Various Types of Valves by GWSSB

Ref: 1. Your proposal dtd. 27-11-2020 for Registration as vendor in Valves

2. Board Meeting No. 284 dtd. 16-4-2021

Sir,

I am pleased to inform that your works located at Village & Post: Mahiserkha, Tusiberia Road (Near Ideal School), PS: Uluberia. Dist: Howrah- 711 303 has been given approval as vendor for purchase of Various Types of Valves as detail mention below by Gujarat Water Supply & Sewerage Board for the use in drinking water system.

Sr. No.	Type of Valve	ISI Mark	Class	Sizes Dia in mm
1.	Sluice Valve	With ISI Mark (IS 14846)	PN 1.0	50 to 1200 mm
			PN 1.6	50 to 600 mm
		Without ISI mark (as per IS 14846)	PN 1.0	Up to 1500
2	Butterfly Valve	With ISI Mark (IS 13095)	PN 1.0 & PN 1.6	40 to 1200 mm
			PN 1.6	1400 to 2000 mm
		Without ISI Mark (IS 13095)	PN 2.0	Up to 1800
3	Air Valve	With ISI Mark (as per IS 14845)	PN 1.0 & PN 1.6	DK:- 40 to 200 mm
4.	Temper Proof Air valve	Without ISI mark (As per AWWA C-512)	PN 1.0 & PN 1.6	40 to 300 mm

Sr. No.	Type of Valve	ISI Mark	Class	Sizes Dia in mm
5.	Dual Plate check valve	Without ISI Mark (As per API 594)	PN 1.6	Up to 1500 mm
6.	Non Return Valve	With ISI mark (as per IS 5312)	PN 1.0 & PN 1.6	50 to 600 mm
		Without ISI mark (As per IS 5312)	PN 1.0	Up to 1600 mm

You have become eligible for participating in bidding process of Gujarat Water Supply & Sewerage Board for purchase of Valves as mention above for turnkey / EPC tender works of GWSSB.

This registration is only for purchase of above commodity by Gujarat Water Supply & Sewerage Board and not for propagation furthering your interest of marketing by publication in news papers or advertising in any form.


The validity of registration will be up to Dt. 25-4-2024. However shifting of works or any addition / alteration activity carried out in works mentioned above will attract fresh shop survey & hence it shall be brought to the notice of GWSSB immediately.

This approval does not mean a guarantee to your firm for purchase of Items mentioned above by Gujarat Water Supply & Sewerage Board. The Gujarat Water Supply & Sewerage Board reserves right for cancellation of your firm from vendor list without assigning any reason.

You should have to apply for renewal/ fresh approval well in advance i.e. three months prior to the expiry date of the registration / approval.

Any discrepancy noticed in this letter should be brought to the notice of GWSSB within 10 days.

Yours sincerely,



Chief Engineer
Material Cell (C)

C.C.to:

- 1 Chief Engineer, Zone – 1,2,3,4,5, 6 /Vadodara /Ahmedabad / Rajkot /Bhuj/Junaghad/ Surat for Information.
2. Chief Engineer Mechanical Cell / Urban Cell, Gandhinagar for Information.
3. Chief General Manager, GWIL, G'nagar for information.
4. WASMO, G'nagar for information.